

浙江衢化氟化学有限公司
ZHEJIANG QUHUA FLUOR-CHEMISTRY CO., LTD.
QUZHOU ZHEJIANG CHINA

CERTIFICATE OF ANALYSIS

TO : IE Maslov Vasily Pavlovich

Goods: RGas 134a
INV. NO: FH0624039-1
PO NO: 1MVJH
DATE: OCT. 22, 2024
EXPIRE DATE: OCT. 21, 2029

TEST ITEMS	Specification	Analysis Results
Inspection Standard	GB/T 18826-2016	
Appearance	Clear, Colorless and Odorless	Clear, Colorless and Odorless
Purity, % by weight	99.5	99.95
Moisture, % by weight	0.001	0.0007
Acidity (as in HCL),mg/kg	0.0001	NO DETECT
Residue on Evaporation, % by weight %	0.005	0.0004
Determination of chlorides(Cl-)	pass	pass
Non-Condensable Gas at 25℃ %	≤1.5	0.8

浙江衢化氟化学有限公司
ZHEJIANG QUHUA FLUOR-CHEMISTRY CO., LTD.

«Рефлог»
«RefLog» LLC
ОПГ. Москва
САНКТ-ПЕТЕРБУРГ

12 米